

SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Jim Doyle, Governor Richard J. Leinenkugel, Secretary

May 14, 2009 RE-ISSUED 06/01/2009 CONTACT CHANGED

ZOELLER PUMP COMPANY WES COMBS 3649 CANE RUN RD LOUISVILLE KY 40211-1961

Re: Description: SEWAGE TREATMENT APPARATUS, EFFLUENT FILTER (see also SEWAGE

TREATMENT TANKS)

Manufacturer: ZOELLER PUMP COMPANY

Product Name: "WW" RESIDENTIAL EFFLUENT FILTER

Model Number(s): 170-0078 Product File No: 20090159

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of SEPTEMBER 2014.

This approval is contingent upon compliance with the following stipulation(s):

- This product may only be installed in the outlet tee baffle of septic tanks or compartments that have a maximum daily flow rate of no more than 1000 gallons per day.
- An access opening of sufficient size to allow removal of the filter must be provided over the outlet tee baffle of which this product is installed. This access opening must terminate at or above grade.
- Maintenance information must be given to the owner of the tank explaining that periodic cleaning of the filter will be necessary.
- This product must be installed in sewage treatment tanks approved by the Department of Commerce, Division of Safety and Buildings for use with this product.
- This product will prevent solids with a size greater than 1/16" in size from passing.
- When this product is installed at a distance greater than thirty inches (30 ") below the top of the access opening, a plastic pipe must be securely attached to the socket on top of the filter. The top of the pipe shall terminate with a tee or ell, which is solvent cemented onto the pipe. The top of the pipe must be at a distance less than thirty inches (30") below the top of the access opening.

This approval supersedes the approval issued on 9/28/2004 under product file number 20040511.

SBD-10564-E (N.10/97) File Ref: 09015905.DOC

ZOELLER PUMP COMPANY Page 2 May 14, 2009 PRODUCT FILE NO. 20090159

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number #20040511.

RE-ISSUED 06/01/2009 CONTACT CHANGED

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.
PO Box 2658
201 W Washington Ave.
Madison WI 53703-2658

Phone: 608-266-0955; Fax: 608-283-7456 E-mail: Jean.MacCubbin@wisconsin.gov